



1. MOUNT INODE INTO ENCLOSURE.
2. ENCLOSURE SHALL HAVE 110 VAC POWER SUPPLY.
3. SET UP CURRENT LOOP WITH FLOW MONITORS 4-20 mA ANALOG OUTPUT.

INODE TELEMETRY FOR PERMANENT MONITORING SITES

NOTE:

1. PURCHASING CONTACT: EMNET, LLC, WWW.EMNET.NET, 121 S. NILES AVE., SOUTH BEND, IN 46617, PHONE: 574.855.1012

NOT TO SCALE

CITY OF JOLIET, ILLINOIS
SEWER FLOW MONITORING
(GRAVITY)

INODE TELEMETRY FOR PERMANENT
MONITORING SITES

SAN-11

DATE: OCT. 2017