



WATER METER
PLAN VIEW
N.T.S.

1. CENTER LINE OF PIPE AT METER TO BE 18" TO 48" ABOVE FLOOR.
2. AMR CONDUIT TO BE 48" ABOVE GROUND LEVEL. LEAVE MINIMUM OF 12" WIRE OUTSIDE HOLE.
3. EXPANSION TANK REQUIRED AFTER DUAL CHECK VALVE BETWEEN SHUT OFF VALVE TO HOT WATER HEATER AND HOT WATER HEATER.
4. FOR NEW CONSTRUCTION, METER COUPLING, DUAL CHECK, AND AMR WIRE PURCHASED FROM CITY.
5. PLUMBER TO INSTALL COPPER PIPING THROUGH ENTIRE METER/VALVE AREA BEFORE CUTTING OUT SECTION FOR METER AND CHECK VALVE.
6. TO BE USED FOR NEW CONSTRUCTION OR AS INSTRUCTED.

NOT TO SCALE

CITY OF JOLIET, ILLINOIS

WATER METER DETAIL
5/8" X 3/4"

WTR-08
DATE: OCT. 2017