

00 91 13

ADDENDUM NO. 2

DATE: November 22, 2022

FROM: Baxter & Woodman, Inc., Consulting Engineers

TO: Planholders of record for the Work titled:

City of Joliet, Illinois
Black Road Acres Phase 1 Water Main Improvements
City of Joliet Contract No. 2680-0123

The Bidding Documents are amended as follows:

1. SPECIFICATIONS

A. Section 01 22 29, MEASUREMENT AND PAYMENT:

Page 01 22 29-13, delete paragraph 1.22.A and replace with the following:

“A. Description:

1. The work of this Pay Item consists of the removal and replacement of existing storm sewers with Class 52 ductile iron pipe or water main quality PVC pipe, including sawcutting, and removal and disposal of existing pavement; protection, repair or replacement of utilities; excavation; removal and disposal of waste excavated material; trench dewatering, including erosion and sedimentation control; watertight connections to existing pipes or structures; installation of pipe; bracing, bedding and covering of pipe; granular trench backfill material at pipe crossing and below all pavement; and cleanup.
2. Where new water main is being installed parallel to storm sewer, the ductile iron or PVC replacement shall extend on each side of the crossing until the perpendicular distance from the water main to the sewer is at least 10 feet.”

Nothing in this Addendum shall be construed as changing other requirements of the Bidding Documents. Each Bidder shall acknowledge receipt of this Addendum by stating this on the outside of the SEALED bid package. BID PROPOSALS SHALL NOT BE OPENED WITHOUT ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS FOR THE GIVEN CONTRACT.

END OF ADDENDUM NO. 2

ADDENDUM NO. 2
00 91 13-1 (211917.40)