

00 91 13

ADDENDUM NO. 2

DATE: November 16, 2023

FROM: Baxter & Woodman, Inc., Consulting Engineers

TO: Planholders of record for the Work titled:

City of Joliet, Illinois
Plainfield Road (Theodore to Black) Water Main Improvements
City of Joliet Contract No. 2766-0124

The Bidding Documents are amended as follows:

1. SPECIFICATIONS

A. Section 01 22 29, MEASUREMENT AND PAYMENT:

Page 01 22 29-7, delete paragraph 1.12.A.4 and replace with the following:

“4. This Pay Item includes providing and installing cast iron frames and covers with self-sealing lids on all valve vaults.”

B. Section 33 11 43, WATER DISTRIBUTION SYSTEM:

Page 33 11 43-7, delete paragraph 2.7.A.1 and replace with the following:

“1. Use two-piece bolted sleeve ductile iron or stainless steel type with mechanical joints.”

C. Section 33 31 43, SANITARY SEWER SYSTEM:

Page 33 31 43-2, delete paragraph 2.1.A.1 and replace with the following:

“1. For pipe and fittings 4-inch through 15-inch:
a. Comply with ASTM D3034 for Type PSM polyvinyl chloride (PVC) sewer pipe and fittings of minimum wall thickness SDR 26.
b. Joints: Use elastomeric gasket type complying with ASTM F477 and ASTM D3212.
c. Gaskets for fittings and joints: Provide minimum cross-sectional area of 0.20 square inches complying with ASTM F477.”

Nothing in this Addendum shall be construed as changing other requirements of the Bidding Documents. Each Bidder shall acknowledge receipt of this Addendum where indicated in the Bid Form.

END OF ADDENDUM NO. 2

ADDENDUM NO. 2
00 91 13-1 (221587.40)